

Determinations and approvals for alternative decontamination procedures, alternative maintenance programs, or drift eliminator exemptions

Regulation 18 of the South Australian Public Health (Legionella) Regulations 2013 (the Legionella Regulations) enables system owners to apply to the Minister for Health and Wellbeing (the Minister) for approval to use an alternative (to a prescribed) maintenance program or decontamination procedure for a particular high risk manufactured water system.

Applications can also be made for a determination by the Minister that cooling towers in a particular system need not be fitted with compliant drift eliminators.

This fact sheet has been developed to assist with the process of applying for an alternative maintenance program or decontamination procedure approval or drift eliminator determination. It explains the minimum information required in an application and should be read in conjunction with the Legionella Regulations and SA Health's Guidelines for the Control of Legionella in Manufactured Water Systems in South Australia (the Legionella Guidelines).

Types of approvals and determinations

There are four types of approval or determination which can be granted under the Legionella Regulations.

- > Alternative decontamination procedure for a warm water system.
- > Alternative decontamination procedure for a cooling water system.
- > Alternative maintenance program for a cooling water system.
- > Determination that cooling towers in a particular system need not be fitted with compliant drift eliminators.

There is no process available to allow for an exemption or deviation from any of the other mandatory requirements of the Legionella Regulations. A determination or approval may be subject to such conditions as the Minister thinks fit. It is an offence to contravene or fail to comply with a condition of an approval or determination and if a condition is contravened or not complied with an approval or determination may be revoked.

Who should complete and submit an application for an approval or determination?

The system owner must submit the application. However, the person responsible for the operation and maintenance of the system may be nominated as the contact person. Due to the complex technical and scientific information which may be required for a successful application, a suitably qualified and experienced consultant may be engaged to assist with the research, evaluation and writing of the proposal.

The prescribed requirements of the Legionella Regulations must be complied with while an approval or determination application is being assessed.

What information is required in an approval application?

Application forms are available for download from the SA Health website, detailing the initial information that must be provided for an application. It is recommended that as much detail as possible is included in the application.



All parts of the form must be completed in full. Additional pages and appendices can be attached to the application if necessary. It is particularly important to provide supporting evidence to back up the rationale for an application.

The applicant must demonstrate that:

- > a proposed alternative decontamination procedure will effectively kill *Legionella* in the system, or a proposed alternative maintenance program will inhibit *Legionella* colonisation equally as well as a prescribed decontamination procedure or maintenance program (whichever is applicable).
- > a robust *Legionella* testing program will be implemented to verify the efficacy of a proposed alternative decontamination procedure or maintenance program if approved / implemented.
- > there is no increased risk to public health associated with a proposed alternative method or drift eliminator exemption.
- > the system in question is being operated and maintained in full compliance with the Legionella Regulations.
- > the system in question has been assessed for risks associated with poor flow and stagnation and modifications have been made and / or risk management protocols have been implemented to address any identified risks.

To assist the application assessment process, the applicant must provide a detailed 'step by step' guide of the proposed methodology.

The methodology should include the following detailed information:

- > Effective CT (concentration and time) values for any proposed biocides (based on concentrations of active ingredients) to be used in an alternative decontamination procedure (supported by reputable scientific sources).
- > Calculations of the necessary biocide volume dosage based on the total capacity of the system, or explanations of how the correct free residual will otherwise be attained, monitored, and maintained.
- > The frequency of proposed maintenance operations and / or conditions for decontamination.

- > All locations from which water will be sampled and flushed.
- > The frequency of sampling / testing to be conducted to indicate the presence of *Legionella* and / or other micro-organisms in the system, including post decontamination sampling.
- > Details of target values for any water chemistry parameters relevant to proposed alternative decontamination procedures or maintenance programs and how they will be monitored and maintained.
- > Reputable and robust scientific evidence supporting the efficacy of the proposed methodology. This evidence should be in the form of credible sources such as peer reviewed journal articles and Australian Standards (copies of all referenced documents must be submitted with the application form).
- > Any other relevant information.

What information is required in a determination application?

The application process for a drift eliminator determination is very similar to that of an approval. A determination is for an exemption to regulation 8 of the Legionella Regulations, which requires compliant drift eliminators to be fitted to all cooling towers.

As an exemption to this regulation will result in a cooling tower being operated without compliant drift eliminators fitted, the potential public health risks must be considered. For an application of this type to be successful, it must demonstrate that any resulting risk to public health will be negligible or non-existent.

It is recommended that applicants provide specific details of any additional risk management strategies proposed to be employed to minimise the risks associated with not having compliant drift eliminators fitted. Applications should also include an assessment of the risks (if any) that would be posed to public health by the operation of the cooling towers in question without compliant drift eliminators.

What is the timeframe for assessing an approval or determination?

SA Health will respond to an application as quickly as possible. A response should not be expected immediately. The time taken for an application to be assessed will depend on the complexity of the application and the workload of officers at the time. It is recommended that applicants apply for an approval or determination at least six months in advance of when they expect to require the approval or determination.

What fees are associated with an approval or determination application?

A fee must be paid when applying, regardless of whether or not the application is ultimately successful. The most up to date schedule of fees is published on SA Health's website:

<http://www.sahealth.sa.gov.au/legionella>

Where can I get application forms?

Application forms can be downloaded from SA Health's website:

<http://www.sahealth.sa.gov.au/legionella>

For more information

Health Protection Programs
SA Health
PO Box 6
RUNDLE MALL SA 5000
Email: HealthProtectionPrograms@sa.gov.au
Telephone: 08 8226 7100

www.sahealth.sa.gov.au



<https://creativecommons.org/licenses>



Government
of South Australia

SA Health